

SYRACUSE CITY SCHOOL DISTRICT
NOTTINGHAM HIGH SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	02/16/24 RESULTS (ppb)	02/16/24 ORIGINAL ACTIONS	LAB RE-SAMPLE I.D. No.	04/12/24 RE-SAMPLE RESULTS (ppb)	04/12/24 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	08/08/24 RE-SAMPLE RESULTS (ppb)	08/08/24 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	10/11/24 RE-SAMPLE RESULTS (ppb)	10/11/24 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	3/07/25 RE-SAMPLE RESULTS (ppb)	03/07/25 RE-SAMPLE ACTIONS
BUILDING 'A'																		
Rm. 46 - Kitchen	Sink	Secured - SCSD Staff Only	015	NM-S131	2.5	None	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 46 - Kitchen	Sink (Hose)	Secured - SCSD Staff Only	014	NM-S132	2.2	None	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 46 - Kitchen	Sink (Hose)	Secured - SCSD Staff Only	013	NM-S133	1.8	None	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 46 - Kitchen	Sink	Secured - SCSD Staff Only	012	NM-S134	6.9	See Note 6.	001	63.6	See Note 6.	001	51.7	See Notes 6 & 7.	001	6.3	See Note 6.	001	<1.0	None
Rm. 46 - Kitchen	Sink	Secured - SCSD Staff Only	010	NM-S136	2.0	None	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 46 - Kitchen	Sink	Secured - SCSD Staff Only	011	NM-S137	2.0	None	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 46 - Kitchen	Sink	Secured - SCSD Staff Only	018	NM-S139	3.4	None	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 46 - Kitchen	Sink (Hose)	Secured - SCSD Staff Only	017	NM-S142	45.3	See Note 7.	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 46 - Kitchen	Sink (Hose)	Secured - SCSD Staff Only	057	NM-S143	6.1	See Note 6.	002	30.5	See Note 6.	002	2.1	None	---	---	---	---	---	---
Rm. 46 - Kitchen	Ice Machine	Secured - SCSD Staff Only	016	NM-S149	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---
Hallway/Corridor - C203	Fountain	Public Access	001	NM-F1006	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---
Hallway/Corridor - C203	Fountain	Public Access	002	NM-F1007	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---
Hallway/Corridor - C204	Fountain	Public Access	003	NM-F1008	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---
Hallway/Corridor - C204	Fountain	Public Access	004	NM-F1009	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---
Hallway/Corridor - C116	Fountain	Public Access	005	NM-F1004	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---
Hallway/Corridor - C116	Fountain	Public Access	006	NM-F1005	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---
Hallway/Corridor - C115	Fountain	Public Access	007	NM-F1002	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---
Hallway/Corridor - C115	Fountain	Public Access	008	NM-F1003	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---
Hallway/Corridor - C106	Fountain	Public Access	009	NM-F202	3.8	None	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 46 - Kitchen	Combitherm (Oven Sprayer)	Secured - SCSD Staff Only	019	NM-C1000	5.9	See Note 6.	005	6.2	See Note 7.	001	3.3	None	---	---	---	---	---	---
Rm. 46 - Kitchen	Combitherm (Oven Sprayer)	Secured - SCSD Staff Only	020	NM-C1001	1.8	None	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 46 - Kitchen	Convotherm (Oven Sprayer)	Secured - SCSD Staff Only	021	NM-C1002	4.4	None	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 46 - Kitchen	Convotherm (Oven Sprayer)	Secured - SCSD Staff Only	---	NM-C1004	---	See Note 9.	003	4.3	None	---	---	---	---	---	---	---	---	---
Hallway/Corridor - C107	Fountain	Public Access	023	NM-F1000	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---
Hallway/Corridor - C107	Fountain	Public Access	024	NM-F1001	2.2	None	---	---	---	---	---	---	---	---	---	---	---	---
Hallway/Corridor - C107	Fountain (Sensor)	Public Access	025	NM-F1001 A	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 102 - Life Skills	Sink	Public Access	051	NM-S1004	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 102 - Life Skills	Sink	Public Access	052	NM-S1003	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 24 - Work Area	Sink	Public Access	053	NM-S1002	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 23 - Exam	Sink	Public Access	054	NM-S1001	1.7	None	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 11 - Main Office	Sink	Secured - SCSD Staff Only	055	NM-S1000	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 46 - Kitchen	Sink	Secured - SCSD Staff Only	056	NM-S135	2.1	None	---	---	---	---	---	---	---	---	---	---	---	---
Hallway/Corridor - C113	Fountain	Public Access	026	NM-F205	2.3	None	---	---	---	---	---	---	---	---	---	---	---	---
Hallway/Corridor - C113	Fountain	Public Access	027	NM-F206	1.3	None	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 69 - Ice/Laundry	Ice Machine	Public Access	028	NM-S253	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---
Hallway/Lobby - C109	Fountain	Public Access	022	NM-F208	2.4	None	---	---	---	---	---	---	---	---	---	---	---	---

SYRACUSE CITY SCHOOL DISTRICT
NOTTINGHAM HIGH SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	02/16/24 RESULTS (ppb)	02/16/24 ORIGINAL ACTIONS	LAB RE-SAMPLE I.D. No.	04/12/24 RE-SAMPLE RESULTS (ppb)	04/12/24 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	08/08/24 RE-SAMPLE RESULTS (ppb)	08/08/24 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	10/11/24 RE-SAMPLE RESULTS (ppb)	10/11/24 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	10/11/24 RE-SAMPLE RESULTS (ppb)	10/11/24 RE-SAMPLE ACTIONS
BUILDING 'B'																		
Rm. GW3 - Classroom Bathroom	Sink	Public Access	041	NM-S115	5.6	See Note 8.	004	3.8	None	---	---	---	---	---	---	---	---	---
Rm. GW5 - Classroom Bathroom	Sink	Public Access	042	NM-S114	4.4	None	---	---	---	---	---	---	---	---	---	---	---	---
Rm. GW6 - Classroom Bathroom	Sink	Public Access	043	NM-S112	3.2	None	---	---	---	---	---	---	---	---	---	---	---	---
Rm. GW7 - Classroom Bathroom	Sink	Public Access	044	NM-S109	3.8	None	---	---	---	---	---	---	---	---	---	---	---	---
Rm. GW9 - Classroom	Sink	Public Access	045	NM-S106	3.7	None	---	---	---	---	---	---	---	---	---	---	---	---
Rm. GW11 - Classroom Bathroom	Sink	Public Access	046	NM-S102	1.7	None	---	---	---	---	---	---	---	---	---	---	---	---
Rm. GW13 - Office	Sink	Secured - SCSD Staff Only	032	NM-S126	4.1	None	---	---	---	---	---	---	---	---	---	---	---	---
Rm. GW14 - Office	Sink	Secured - SCSD Staff Only	033	NM-S124	5.0	None	---	---	---	---	---	---	---	---	---	---	---	---
Hallway/Corridor - C125	Fountain	Public Access	035	NM-F101A	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---
Hallway/Corridor - C125	Fountain	Public Access	034	NM-F101B	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---
Rm. GW21 - Shop	Sink	Public Access	030	NM-S2001	4.8	None	---	---	---	---	---	---	---	---	---	---	---	---
Hallway/Corridor - C127	Fountain	Public Access	031	NM-F2000	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---
Rm. GW4 - Project L.T.W. Classroom	Sink	Public Access	036	NM-S2010	6.6	See Note 7.	---	---	---	---	---	---	---	---	---	---	---	---
Rm. GW4 - Project L.T.W. Classroom	Sink	Public Access	037	NM-S2011	2.6	None	---	---	---	---	---	---	---	---	---	---	---	---
Rm. GW4 - Project L.T.W. Classroom	Sink	Public Access	038	NM-S2012	1.1	None	---	---	---	---	---	---	---	---	---	---	---	---
Rm. GW4 - Project L.T.W. Classroom	Sink	Public Access	039	NM-S2007	2.6	None	---	---	---	---	---	---	---	---	---	---	---	---
Rm. GW4 - Project L.T.W. Classroom	Sink	Public Access	040	NM-S2008	2.6	None	---	---	---	---	---	---	---	---	---	---	---	---
Hallway/Lobby - C120	Fountain	Public Access	048	NM-F2001	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---
Hallway/Lobby - C120	Fountain	Public Access	049	NM-F2002	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---
Rm. GW21 - Shop	Sink	Public Access	029	NM-S2001 A	2.9	None	---	---	---	---	---	---	---	---	---	---	---	---
Hallway/Lobby - C120	Fountain	Public Access	047	NM-F321	8.3	See Note 7.	---	---	---	---	---	---	---	---	---	---	---	---
Rm. P-137 - Swimming Pool Area	Fountain	Public Access	050	NM-F328	1.7	None	---	---	---	---	---	---	---	---	---	---	---	---

Notes [February 16, 2024 Event]:

- Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-028.
- Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70287757.
- New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
- The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
- Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
- Fixture repaired by SCSD.
- Fixture removed by SCSD.
- Fixture signed by SCSD. No further action required.
- Fixture not sampled on 02/16/2024.

Notes [April 12, 2024 Event]:

- Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-028.
- Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70294201.
- New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
- The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
- Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
- Fixture removed and replaced by SCSD.
- Fixture repaired by SCSD.

SYRACUSE CITY SCHOOL DISTRICT
NOTTINGHAM HIGH SCHOOL

Notes [August 8, 2024 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-028.
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70308211 & 70309138
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Sample obtained on August 14, 2024.
7. Fixture repaired by SCSD.

Notes [October 11, 2024 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-028.
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70317756.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. SCSD to evaluate fixture for repair or removal.

Notes [March 7, 2025 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-028.
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70341940.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.