

SYRACUSE CITY SCHOOL DISTRICT  
DELAWARE ELEMENTARY SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	06/22/23 RESULTS (ppb)	06/22/23 ORIGINAL ACTIONS	LAB RE-SAMPLE I.D. No.	01/09/24 RE-SAMPLE RESULTS (ppb)	01/09/24 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	03/08/24 RE-SAMPLE RESULTS (ppb)	03/08/24 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	05/09/25 RE-SAMPLE RESULTS (ppb)	05/09/25 RE-SAMPLE ACTIONS
Rm. 101 - Classroom	Sink	Public Access	042	DE-S332	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 101 - Classroom	Fountain	Public Access	043	DE-F310	2.9	None	---	---	---	---	---	---	---	---	---
Rm. 102 - Classroom	Sink	Public Access	040	DE-S330	137	See Note 7.	017	<1.0	None	---	---	---	---	---	---
Rm. 102 - Classroom	Fountain	Public Access	041	DE-F309	9.7	See Note 6.	016	1.3	None	---	---	---	---	---	---
Rm. 103 - Classroom	Sink	Public Access	038	DE-S325	226	See Note 7.	015	<1.0	None	---	---	---	---	---	---
Rm. 103 - Classroom	Fountain	Public Access	039	DE-F307	10.5	See Note 6.	014	<1.0	None	---	---	---	---	---	---
Rm. 104 - Classroom	Fountain	Public Access	025	DE-F306	216	See Note 6.	012	<1.0	None	---	---	---	---	---	---
Rm. 104A - Classroom Bathroom	Sink	Public Access	024	DE-S323	2.3	None	---	---	---	---	---	---	---	---	---
Rm. 105 - Classroom	Fountain	Public Access	027	DE-F308	127	See Note 6.	013	<1.0	None	---	---	---	---	---	---
Rm. 105A - Classroom Bathroom	Sink	Public Access	026	DE-S327	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 108 - Classroom	Sink	Public Access	023	DE-S320	26.2	See Note 7.	011	<1.0	None	---	---	---	---	---	---
Rm. 108 - Classroom	Fountain	Public Access	022	DE-F304	127	See Note 6.	010	<1.0	None	---	---	---	---	---	---
Rm. 110 - Classroom	Sink	Public Access	019	DE-S318	34.3	See Note 7.	009	<1.0	None	---	---	---	---	---	---
Rm. 110 - Classroom	Fountain	Public Access	020	DE-F303	17.7	See Note 6.	008	4.1	None	---	---	---	---	---	---
Rm. 112 - Classroom	Sink	Public Access	017	DE-S316	26.9	See Note 7.	018	45.1	See Note 7.	001	7.7	See Note 6.	---	---	---
Rm. 112 - Classroom	Fountain	Public Access	016	DE-F302	5.3	See Note 6.	---	---	See Note 6.	---	3.9 <sup>7</sup>	None	---	---	---
Rm. 118 - Teacher's Lounge	Sink	Secured - SCSD Staff Only	015	DE-S306	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 120 - Serving Room	Sink	Secured - SCSD Staff Only	034	DE-S301	5.2	See Note 7.	004	<1.0	None	---	---	---	---	---	---
Rm. 120 - Serving Room	Sink	Secured - SCSD Staff Only	035	DE-S302	4.6	None	---	---	---	---	---	---	---	---	---
Rm. 120 - Serving Room	Sink	Secured - SCSD Staff Only	036	DE-S303	1.6	None	---	---	---	---	---	---	---	---	---
Rm. 120 - Serving Room	Sink	Secured - SCSD Staff Only	037	DE-S304	128	See Note 6.	001	<1.0	None	---	---	---	---	---	---
Rm. 120A - Kitchen Bathroom	Sink	Secured - SCSD Staff Only	011	DE-S305	3.7	None	002	1.5	None	---	---	---	---	---	---
Rm. 123A - Hallway/Corridor	Fountain	Public Access	013	DE-F301	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 123A - Hallway/Corridor	Fountain	Public Access	014	DE-F301A	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 129 - Hallway/Corridor	Fountain	Public Access	021	DE-F305	6.1	See Note 6.	007	1.2	None	---	---	See Note 8.	013	<1.0	None
Rm. 129 - Hallway/Corridor	Bottle Fill	Public Access	---	DE-F305A	---	---	---	---	---	---	---	See Note 8.	006	<1.0	None
Rm. 190A - Classroom Bathroom	Sink	Public Access	018	DE-S317	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 232 - Hallway/Corridor	Fountain	Public Access	033	DE-F311	<1.0	None	---	---	---	---	---	See Note 8.	015	<1.0	None
Rm. 232 - Hallway/Corridor	Bottle Fill	Public Access	---	DE-F311A	---	---	---	---	---	---	---	See Note 8.	014	<1.0	None

SYRACUSE CITY SCHOOL DISTRICT  
DELAWARE ELEMENTARY SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	06/22/23 RESULTS (ppb)	06/22/23 ORIGINAL ACTIONS	LAB RE-SAMPLE I.D. No.	01/09/24 RE- SAMPLE RESULTS (ppb)	01/09/24 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	03/08/24 RE-SAMPLE RESULTS (ppb)	03/08/24 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	05/09/25 RE-SAMPLE RESULTS (ppb)	05/09/25 RE-SAMPLE ACTIONS
Rm. 235 - Hallway/Vestibule	Sink	Public Access	030	DE-S334	739	See Note 7.	042	<1.0	None	---	---	---	---	---	---
Rm. 235 - Hallway/Vestibule	Sink	Public Access	031	DE-S335	583	See Note 7.	043	<1.0	None	---	---	---	---	---	---
Rm. 235 - Hallway/Vestibule	Sink	Public Access	032	DE-S336	215	See Note 7.	044	<1.0	None	---	---	---	---	---	---
Rm. 240 - Hallway/Vestibule	Sink	Public Access	050	DE-S346	2100	See Note 7.	030	<1.0	None	---	---	---	---	---	---
Rm. 240 - Hallway/Vestibule	Sink	Public Access	051	DE-S347	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 240 - Hallway/Vestibule	Sink	Public Access	052	DE-S348	921	See Note 7.	031	<1.0	None	---	---	---	---	---	---
Rm. 240 - Hallway/Vestibule	Sink	Public Access	053	DE-S349	211	See Note 7.	032	<1.0	None	---	---	---	---	---	---
Rm. 240 - Hallway/Vestibule	Fountain	Public Access	044	DE-F312	<1.0	None	---	---	---	---	---	See Note 8.	011	<1.0	None
Rm. 240 - Hallway/Vestibule	Bottle Fill	Public Access	---	DE-F312A	---	---	---	---	---	---	---	See Note 8.	012	<1.0	None
Rm. 245 - Gym Lobby	Fountain	Public Access	049	DE-F313	<1.0	None	---	---	---	---	---	See Note 8.	009	<1.0	None
Rm. 245 - Gym Lobby	Bottle Fill	Public Access	---	DE-F313A	---	---	---	---	---	---	---	See Note 8.	010	<1.0	None
Rm. 306A - Classroom Bathroom	Sink	Public Access	009	DE-S359	405	See Note 7.	026	<1.0	None	---	---	---	---	---	---
Rm. 308A - Classroom Bathroom	Sink	Public Access	008	DE-S358	<1.0	None	---	---	None	---	---	---	---	---	---
Rm. 319 - Work Room	Sink	Public Access	002	DE-S352	689	See Note 7.	020	<1.0	None	---	---	---	---	---	---
Rm. 324A - Hallway/Corridor	Fountain	Public Access	001	DE-F314	107	See Note 6.	019	<1.0	None	---	---	See Note 8.	003	<1.0	None
Rm. 324A - Hallway/Corridor	Bottle Fill	Public Access	---	DE-F314A	---	---	---	---	---	---	---	See Note 8.	002	<1.0	None
Rm. 330A - Hallway/Vestibule	Fountain	Public Access	010	DE-F317	1.3	None	---	---	---	---	---	See Note 8.	001	<1.0	None
Rm. 330A - Hallway/Vestibule	Bottle Fill	Public Access	---	DE-F317A	---	---	---	---	---	---	---	See Note 8.	007	<1.0	None
Rm. 335 - Hallway/Vestibule	Sink	Public Access	045	DE-S360	423	See Note 7.	027	<1.0	None	---	---	---	---	---	---
Rm. 335 - Hallway/Vestibule	Sink	Public Access	046	DE-S361	200	See Note 7.	028	<1.0	None	---	---	---	---	---	---
Rm. 335 - Hallway/Vestibule	Sink	Public Access	047	DE-S362	257	See Note 7.	029	<1.0	None	---	---	---	---	---	---
Rm. 340 - Hallway/Vestibule	Sink	Public Access	003	DE-S354	1360	See Note 7.	021	<1.0	None	---	---	---	---	---	---
Rm. 340 - Hallway/Vestibule	Sink	Public Access	004	DE-S355	330	See Note 7.	022	<1.0	None	---	---	---	---	---	---
Rm. 340 - Hallway/Vestibule	Sink	Public Access	006	DE-S356	1330	See Note 7.	023	<1.0	None	---	---	---	---	---	---
Rm. 340 - Hallway/Vestibule	Sink	Public Access	007	DE-S357	250	See Note 7.	024	<1.0	None	---	---	---	---	---	---
Rm. 340 - Hallway/Vestibule	Fountain	Public Access	005	DE-F315	9.5	See Note 6.	025	<1.0	None	---	---	See Note 8.	008	<1.0	None
Rm. 340 - Hallway/Vestibule	Bottle Fill	Public Access	---	DE-F315A	---	---	---	---	---	---	---	See Note 8.	016	<1.0	None
Rm. 429 - Hallway/Corridor	Fountain	Public Access	048	DE-F316	3.5	None	---	---	---	---	---	See Note 8.	005	<1.0	None
Rm. 429 - Hallway/Corridor	Bottle Fill	Public Access	---	DE-F316A	---	---	---	---	---	---	---	See Note 8.	004	<1.0	None
Rm. 120 - Serving Room	Convotherm Oven	Secured - SCSD Staff Only	012	DE-C1000A	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 206B - Clinical Lab	Sink (Spray Hose)	Public Access	029	DE-S1002	598	See Note 7.	035	1.8	None	---	---	---	---	---	---

SYRACUSE CITY SCHOOL DISTRICT  
DELAWARE ELEMENTARY SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	06/22/23 RESULTS (ppb)	06/22/23 ORIGINAL ACTIONS	LAB RE-SAMPLE I.D. No.	01/09/24 RE-SAMPLE RESULTS (ppb)	01/09/24 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	03/08/24 RE-SAMPLE RESULTS (ppb)	03/08/24 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	05/09/25 RE-SAMPLE RESULTS (ppb)	05/09/25 RE-SAMPLE ACTIONS
Rm. 209 - Nurse's Room - Bathroom	Sink	Public Access	028	DE-S344	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 209 - Nurse's Room	Sink	Public Access	054	DE-S345	254	See Note 7.	033	<1.0	None	---	---	---	---	---	---
Rm. 209 - Nurse's Room	Sink	Public Access	---	DE-S345A	---	None	034	2.6	None	---	---	---	---	---	---
Rm. 206B - Clinical Lab	Sink	Public Access	---	DE-S341	---	None	036	1.1	None	---	---	---	---	---	---
Rm. 206A - Clinic Bathroom	Sink	Public Access	---	DE-S342	---	None	037	<1.0	None	---	---	---	---	---	---
Rm. 206D - Dental Room	Sink	Public Access	---	DE-S339	---	None	038	<1.0	None	---	---	---	---	---	---
Rm. 206C - Treatment Center	Sink	Public Access	---	DE-S340	---	None	039	<1.0	None	---	---	---	---	---	---
Rm. 206F - Nurse's Room	Sink	Public Access	---	DE-S337	---	None	040	7.5	See Note 7.	002	4.1	None	---	---	---
Rm. 206E - Sick/Rest Room	Sink	Public Access	---	DE-S338	---	None	041	<1.0	None	---	---	---	---	---	---
Rm. 112A - Classroom Bathroom	Sink	Public Access	---	DE-S315	---	None	006	<1.0	None	---	---	---	---	---	---

Notes [June 22, 2023 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-022.
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70260836.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture repaired by SCSD.
7. Fixture removed and replaced by SCSD.

Notes [January 09, 2024 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-022.
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70283643.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture repaired by SCSD.
7. Fixture replaced by SCSD.

# SYRACUSE CITY SCHOOL DISTRICT DELAWARE ELEMENTARY SCHOOL

Notes [March 08, 2024 Event]:

- 1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-022.
- 2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70283643.
- 3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
- 4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
- 5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
- 6. Fixture removed by SCSD.
- 7. Sample taken on 03/28/2024.
- 8. Fountain removed and replaced with combined fountain/bottle fill water station.

Notes [May 09, 2025 Event]:

- 1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-022.
- 2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70354066.
- 3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
- 4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
- 5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.