

SYRACUSE CITY SCHOOL DISTRICT PORTER ELEMENTARY SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	06/23/23 RESULTS (ppb)	06/23/23 ORIGINAL ACTIONS	LAB RE-SAMPLE I.D. No.	01/19/24 RE-SAMPLE RESULTS (ppb)	01/19/24 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	06/17/25 RE-SAMPLE RESULTS (ppb)	06/17/25 RE-SAMPLE ACTIONS
Rm. 001 - Hallway/Corridor	Fountain	Public Access	012	PR-F303	<1.0	None	---	---	---	005	<1.0	None.
Rm. 001 - Hallway/Corridor	Fountain (Bottle Fill)	Public Access	---	PR-F303A	---	---	---	---	---	006	<1.0	None.
Rm. 001C - Hallway/Corridor	Fountain	Public Access	007	PR-F302	<1.0	None	---	---	---	003	<1.0	None.
Rm. 001C - Hallway/Corridor	Fountain (Bottle Fill)	Public Access	---	PR-F302A	---	---	---	---	---	004	<1.0	None.
Rm. 001C - Hallway/Corridor	Fountain	Public Access	006	PR-F301	<1.0	None	---	---	---	001	<1.0	None.
Rm. 001C - Hallway/Corridor	Fountain (Bottle Fill)	Public Access	---	PR-F301A	---	---	---	---	---	002	<1.0	None.
Rm. 004A - Classroom Bathroom	Sink	Public Access	009	PR-S311	<1.0	None	---	---	---	---	---	---
Rm. 005A - Classroom Bathroom	Sink	Public Access	008	PR-S310	<1.0	None	---	---	---	---	---	---
Rm. 010 - Serving Room	Combitherm Oven Sprayer	Secured - SCSD Staff Only	005	PR-S400A	4.2	None	---	---	---	---	---	---
Rm. 010 - Serving Room	Sink	Secured - SCSD Staff Only	003	PR-S306	<1.0	None	---	---	---	---	---	---
Rm. 010 - Serving Room	Sink	Secured - SCSD Staff Only	002	PR-S307	<1.0	None	---	---	---	---	---	---
Rm. 010 - Serving Room	Sink	Secured - SCSD Staff Only	001	PR-S308	1.2	None	---	---	---	---	---	---
Rm. 010 - Serving Room	Sink	Secured - SCSD Staff Only	004	PR-S309	<1.0	None	---	---	---	---	---	---
Rm. 014A - Classroom Bathroom	Sink	Public Access	010	PR-S312	1.5	None	---	---	---	---	---	---
Rm. 021A - Classroom Bathroom	Sink	Public Access	018	PR-S319	<1.0	None	---	---	---	---	---	---
Rm. 022 - Classroom	Fountain	Public Access	019	PR-F305	<1.0	None	---	---	---	---	---	---
Rm. 022B - Classroom Bathroom	Sink	Public Access	020	PR-S322	<1.0	None	---	---	---	---	---	---
Rm. 024 - Classroom	Sink	Public Access	014	PR-S321	<1.0	None	---	---	---	---	---	---
Rm. 024 - Classroom	Fountain	Public Access	016	PR-F304	1.2	None	---	---	---	---	---	---
Rm. 024A - Classroom Bathroom	Sink	Public Access	015	PR-S320	2.0	None	---	---	---	---	---	---
Rm. 025A - Classroom Bathroom	Sink	Public Access	017	PR-S318	1.8	None	---	---	---	---	---	---
Rm. 026 - Staff's Lounge	Sink	Secured - SCSD Staff Only	013	PR-S314	<1.0	None	---	---	---	---	---	---
Rm. 036B - Hallway/Corridor	Fountain	Public Access	011	PR-F306	11.1	See Note 7.	001	1.1	None.	---	---	---
Rm. 101 - Hallway/Corridor	Fountain	Public Access	030	PR-F307	<1.0	None	---	---	---	---	---	---
Rm. 101 - Hallway/Corridor	Fountain (Bottle Fill)	Public Access	031	PR-F307A	<1.0	None	---	---	---	---	---	---
Rm. 106 - Classroom	Sink	Public Access	028	PR-S331	2.2	None	---	---	---	---	---	---
Rm. 110A - Library Office	Sink	Secured - SCSD Staff Only	029	PR-S326	3.6	None	---	---	---	---	---	---
Rm. 119 - Hallway/Vestibule	Sink	Public Access	033	PR-S342	<1.0	None	---	---	---	---	---	---
Rm. 119 - Hallway/Vestibule	Sink	Public Access	034	PR-S344	<1.0	None	---	---	---	---	---	---
Rm. 125A - Exam Room	Sink	Public Access	032	PR-S340	<1.0	None	---	---	---	---	---	---
Rm. 201 - Hallway/Corridor	Fountain	Public Access	022	PR-F308	<1.0	None	---	---	---	007	<1.0	None.
Rm. 201 - Hallway/Corridor	Fountain (Bottle Fill)	Public Access	---	PR-F308A	---	---	---	---	---	008	<1.0	None.

SYRACUSE CITY SCHOOL DISTRICT PORTER ELEMENTARY SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	06/23/23 RESULTS (ppb)	06/23/23 ORIGINAL ACTIONS	LAB RE-SAMPLE I.D. No.	01/19/24 RE-SAMPLE RESULTS (ppb)	01/19/24 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	06/17/25 RE-SAMPLE RESULTS (ppb)	06/17/25 RE-SAMPLE ACTIONS
Rm. 203 - Classroom	Sink	Public Access	023	PR-S351	1.4	None	---	---	---	---	---	---
Rm. 206 - Classroom	Sink	Public Access	036	PR-S350	<1.0	None	---	---	---	---	---	---
Rm. 212 - Classroom	Sink	Public Access	035	PR-S349	<1.0	None	---	---	---	---	---	---
Rm. 221 - Hallway/Vestibule	Sink	Public Access	024	PR-S358	<1.0	None	---	---	---	---	---	---
Rm. 221 - Hallway/Vestibule	Sink	Public Access	025	PR-S359	2.6	None	---	---	---	---	---	---
Rm. 221 - Hallway/Vestibule	Sink	Public Access	026	PR-S360	<1.0	None	---	---	---	---	---	---
Rm. 222 - Classroom	Sink	Public Access	027	PR-S361	<1.0	None	---	---	---	---	---	---
Rm. 228 - Classroom	Sink	Public Access	037	PR-S353	21.8	See Note 6.	004	10.8	See Note 6.	---	---	---
Rm. 228 - Classroom	Sink	Public Access	021	PR-S354	10.3	See Note 6.	005	6.6	See Note 6.	---	---	---
Rm. 127 - Parent's Room	Sink	Public Access	---	PR-S337	---	---	002	<1.0	---	---	---	---
Rm. 226 - Classroom	Sink	Public Access	---	PR-S355	---	---	003	2.4	---	---	---	---

Notes [June 23, 2023 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-020.
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70260958.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture removed and replaced by SCSD. Resampling pending.
7. Fixture repaired by SCSD. Resampling pending.

Notes [January 19, 2024 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-020.
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70284765.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture signed by SCSD. No further action required.

SYRACUSE CITY SCHOOL DISTRICT PORTER ELEMENTARY SCHOOL

Notes [June 17, 2025 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-020.
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70361813.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.