

SYRACUSE CITY SCHOOL DISTRICT
LEVY K-8 SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	11/07/24 RESULTS (ppb)	11/07/24 ORIGINAL ACTIONS	LAB RE-SAMPLE I.D. No.	03/07/25 RE-SAMPLE RESULTS (ppb)	03/07/2025 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	05/09/25 RE-SAMPLE RESULTS (ppb)	05/09/2025 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	07/08/25 RE-SAMPLE RESULTS (ppb)	07/08/2025 RE-SAMPLE ACTIONS
Rm. 108 - Classroom	Sink	Public Access	026	LY-S218	1.1	None	---	---	---	---	---	---	---	---	---
Rm. 111A - Hallway/Corridor	Fountain	Public Access	034	LY-F205	2.4	None	---	---	---	---	---	---	---	---	---
Rm. 120 - Hallway/Corridor	Fountain	Public Access	024	LY-F202	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 120 - Hallway/Corridor	Fountain (Sensor)	Public Access	020	LY-F202A	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 121A - Classroom	Fountain	Public Access	017	LY-F203	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 121A - Classroom	Sink	Public Access	021	LY-S208	4.0	None	---	---	---	---	---	---	---	---	---
Rm. 125D - Work Room	Sink	Secured - SCSD Staff Only	033	LY-S203	3.0	None	---	---	---	---	---	---	---	---	---
Rm. 126 - Guidance Office	Sink	Public Access	027	LY-S202	3.6	None	---	---	---	---	---	---	---	---	---
Rm. 129C-1 - Work Room	Sink	Secured - SCSD Staff Only	031	LY-S207	5.7	See Note 6.	008	5.0	None	---	---	---	---	---	---
Rm. 132A - Clinic Office	Sink	Public Access	022	LY-S209	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 135A - Hallway/Corridor	Fountain	Public Access	035	LY-F201	1.3	None	---	---	---	---	---	---	---	---	---
Rm. 142 - Hallway/Corridor	Fountain	Public Access	023	LY-F100	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 151 - Kitchen	Sink	Secured - SCSD Staff Only	025	LY-S115	11.0	See Note 6.	009	7.4	See Note 6.	001	10.7	See Note 6.	001	3.1	None
Rm. 151 - Kitchen	Sink	Secured - SCSD Staff Only	036	LY-S116	3.3	None	---	---	---	---	---	---	---	---	---
Rm. 151 - Kitchen	Sink	Secured - SCSD Staff Only	032	LY-S117	6.0	See Note 6.	010	1.6	None	---	---	---	---	---	---
Rm. 151 - Kitchen	Sink	Secured - SCSD Staff Only	015	LY-S118	4.1	None	---	---	---	---	---	---	---	---	---
Rm. 154 - Cafeteria	Fountain	Public Access	018	LY-F102	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 211A - Hallway/Corridor	Fountain	Public Access	009	LY-F206	3.2	None	---	---	---	---	---	---	---	---	---
Rm. 221 - Classroom	Sink	Public Access	006	LY-S122	5.8	See Note 6.	004	2.4	None	---	---	---	---	---	---
Rm. 221 - Classroom	Sink (hot water only)	Public Access	010	LY-S123	4.8	None	---	---	---	---	---	---	---	---	---
Rm. 230 - Hallway/Corridor	Fountain	Public Access	003	LY-F103	16.0	See Note 6.	005	1.3	None	---	---	---	---	---	---
Rm. 311 - Hallway/Corridor	Fountain	Public Access	013	LY-F207A	1.7	None	---	---	---	---	---	---	---	---	---
Rm. 311B - Hallway/Corridor	Fountain	Public Access	011	LY-F208	3.7	None	---	---	---	---	---	---	---	---	---
Rm. 319 - Classroom	Sink	Public Access	012	LY-S228	2.2	None	---	---	---	---	---	---	---	---	---
Rm. 151 - Kitchen	Convotherm Oven	Secured - SCSD Staff Only	028	LY-C1000	4.5	None	---	---	---	---	---	---	---	---	---
Rm. 319 - Classroom	Sink	Public Access	008	LY-S3000	1.1	None	---	---	---	---	---	---	---	---	---
Rm. 217 - Culinary Room	Sink	Public Access	014	LY-S3001	3.2	None	---	---	---	---	---	---	---	---	---
Rm. 145 - Boy's Locker Room	Sink	Public Access	029	LY-S1000	5.1	See Note 6.	006	5.4	See Note 6.	002	<1.0	None	---	---	---
Rm. 211B - Hallway/Corridor	Fountain	Public Access	005	LY-F207B	7.4	See Note 6.	003	<1.0	None	---	---	---	---	---	---
Rm. 221 - Classroom	Sink (Spray)	Public Access	007	LY-S3002	3.2	None	---	---	---	---	---	---	---	---	---
Rm. 301 - Classroom	Sink	Public Access	004	LY-S1004	14.0	See Note 6.	001	10.3	See Note 1.	---	---	---	---	---	---
Rm. 301 - Classroom	Sink	Public Access	002	LY-S1005	8.7	See Note 6.	002	2.5	None	---	---	---	---	---	---
Rm. 228A - Culinary Room	Sink	Public Access	030	LY-S1003	2.0	None	---	---	---	---	---	---	---	---	---
Rm. 228A - Culinary Room	Sink	Public Access	001	LY-S1002	1.8	None	---	---	---	---	---	---	---	---	---
Rm. 145 - Boy's Locker Room	Fountain	Public Access	019	LY-F101	4.1	None	---	---	---	---	---	---	---	---	---
Rm. 145 - Boy's Locker Room	Sink	Public Access	016	LY-S1001	9.9	See Note 6.	007	4.8	None	---	---	---	---	---	---

SYRACUSE CITY SCHOOL DISTRICT
LEVY K-8 SCHOOL

Notes [November 07, 2024 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-038
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70321290
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture repaired or replaced by SCSD.

Notes [March 07, 2025 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-038A
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70341941
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture repaired or replaced by SCSD.
7. Fixture Signed by SCSD.

Notes [May 09, 2025 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-038A
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70354065
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. SCSD to evaluate fixture for repair or removal.

Notes [July 08, 2025 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-038
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70365851
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.