

**SYRACUSE CITY SCHOOL DISTRICT
FRANKLIN ELEMENTARY SCHOOL**

ROOM No. & LOCATION	Fixture (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	07/21/23 RESULTS (ppb)	07/21/23 ORIGINAL ACTIONS	LAB RE-SAMPLE I.D. No.	04/03/24 RE-SAMPLE RESULTS (ppb)	04/03/24 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	10/22/25 RE-SAMPLE RESULTS (ppb)	10/22/25 RE-SAMPLE ACTIONS
Rm. A100 - Hallway/Vestibule	Fountain	Public Access	012	FN-F207	<1.0	None	---	---	---	---	---	---
Rm. A100 - Hallway/Vestibule	Fountain	Public Access	013	FN-F207A	<1.0	None	---	---	---	---	---	---
Rm. 201 - Nurse Office	Fountain	Public Access	014	FN-S208	<1.0	None	---	---	---	---	---	---
Rm. 100 - Classroom	Sink	Public Access	037	FN-S203	2.5	None	---	---	---	---	---	---
Rm. 100 - Classroom	Fountain	Public Access	036	FN-F204	<1.0	None	---	---	---	---	---	---
Rm. 102 - Classroom	Fountain	Public Access	038	FN-F205	14.7	See Note 6.	003	2.2	None	---	---	---
Rm. 103 - Classroom	Sink	Public Access	046	FN-S205	2.2	None	---	---	---	---	---	---
Rm. 103 - Classroom	Fountain	Public Access	045	FN-F206	2.4	None	---	---	---	---	---	---
Rm. 104 - Classroom	Sink	Public Access	048	FN-S110	1.4	None	---	---	---	---	---	---
Rm. 104 - Classroom	Fountain	Public Access	047	FN-F107	5.7	See Note 6.	004	<1.0	None	---	---	---
Rm. 106 - Classroom	Sink	Public Access	050	FN-S109	1.6	None	---	---	---	---	---	---
Rm. 106 - Classroom	Fountain	Public Access	049	FN-F106	4.8	None	---	---	---	---	---	---
Rm. 112 - Classroom	Sink	Public Access	051	FN-S107	1.4	None	---	---	---	---	---	---
Rm. 112 - Classroom	Fountain	Public Access	052	FN-F105	132	See Note 6.	005	<1.0	None	---	---	---
Rm. 113 - Classroom	Fountain	Public Access	053	FN-F104	3.7	None	---	---	---	---	---	---
Rm. 114 - Classroom	Sink	Public Access	055	FN-S105	2	None	---	---	---	---	---	---
Rm. 114 - Classroom	Fountain	Public Access	056	FN-F103	6.7	See Note 6.	006	<1.0	None	---	---	---
Rm. 116 - Classroom	Fountain	Public Access	057	FN-F102	4.5	None	---	---	---	---	---	---
Rm. 117 - Classroom	Fountain	Public Access	059	FN-F101	3.7	None	---	---	---	---	---	---
Rm. 119 - Hallway/Vestibule	Sink	Public Access	058	FN-S100	<1.0	None	---	---	---	---	---	---
Rm. 119 - Hallway/Vestibule	Sink	Public Access	060	FN-S101	<1.0	None	---	---	---	---	---	---
Rm. 119 - Hallway/Vestibule	Sink	Public Access	061	FN-S102	<1.0	None	---	---	---	---	---	---
Rm. 119 - Hallway/Vestibule	Fountain	Public Access	054	FN-F100	1.2	None	---	---	---	---	---	---
Rm. 201 - Nurse Office	Sink	Public Access	015	FN-S209	5.8	See Note 6.	002	<1.0	None	---	---	---
Rm. 123 - Classroom	Fountain	Public Access	062	FN-F200	<1.0	None	---	---	---	---	---	---
Rm. 202 - Health Center	Sink	Public Access	019	FN-S212A	8.8	See Note 8.	---	---	---	---	---	---
Rm. 124 - Classroom	Fountain	Public Access	063	FN-F201	<1.0	None	---	---	---	---	---	---
Rm. 208 - Teacher's Lounge	Sink	Public Access	022	FN-S130	2.4	None	---	---	---	---	---	---
Rm. 125 - Classroom	Fountain	Public Access	034	FN-F203	<1.0	None	---	---	---	---	---	---
Rm. 131 - Kitchen	Sink	Secured - SCSD Staff Only	044	FN-S112	1.5	None	---	---	---	---	---	---
Rm. 131 - Kitchen	Sink	Secured - SCSD Staff Only	040	FN-S113	2.8	None	---	---	---	---	---	---

**SYRACUSE CITY SCHOOL DISTRICT
FRANKLIN ELEMENTARY SCHOOL**

ROOM No. & LOCATION	Fixture (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	07/21/23 RESULTS (ppb)	07/21/23 ACTIONS	LAB RE-SAMPLE I.D. No.	04/03/24 RE-SAMPLE RESULTS (ppb)	04/03/24 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	10/22/25 RE-SAMPLE RESULTS (ppb)	10/22/25 RE-SAMPLE ACTIONS
Rm. 131 - Kitchen	Sink	Secured - SCSD Staff Only	039	FN-S114	2.2	None	---	---	---	---	---	---
Rm. 131 - Kitchen	Sink	Secured - SCSD Staff Only	041	FN-S115	1	None	---	---	---	---	---	---
Rm. 146C - Cafeteria Passage	Fountain	Public Access	043	FN-F202	<1.0	None	---	---	See Note 6.	001	<1.0	None.
Rm. 146C - Cafeteria Passage	Bottle Fill	Public Access	---	FN-F202A	---	---	---	---	---	002	<1.0	None.
Rm. 125 - Classroom	Sink	Public Access	035	FN-S202	3	None	---	---	---	---	---	---
Rm. 202 - Clinic Room	Sink	Public Access	017	FN-S211	2.4	None	---	---	---	---	---	---
Rm. 202 - Clinic Room	Sink	Public Access	018	FN-S212	2.4	None	---	---	---	---	---	---
Rm. 202 - Clinic/Examination Room	Sink	Public Access	020	FN-S213	2.2	None	---	---	---	---	---	---
Rm. 202 - Clinic Room	Sink	Public Access	021	FN-S215	1.5	None	---	---	---	---	---	---
Rm. 204 - Clinic Room	Sink	Public Access	016	FN-S210	1.7	None	---	---	---	---	---	---
Rm. 124 - Classroom	Sink	Public Access	064	FN-S201	2.3	None	---	---	---	---	---	---
Rm. 210 - Classroom	Sink	Public Access	032	FN-FA	<1.0	None	---	---	---	---	---	---
Rm. 212D - Hallway/Vestibule	Sink	Public Access	023	FN-S122	<1.0	None	---	---	---	---	---	---
Rm. 212D - Hallway/Vestibule	Sink	Public Access	024	FN-S123	3.8	None	---	---	---	---	---	---
Rm. 212D - Hallway/Vestibule	Sink	Public Access	026	FN-S124	<1.0	None	---	---	---	---	---	---
Rm. 212D - Hallway/Vestibule	Fountain	Public Access	025	FN-F108	<1.0	None	---	---	---	---	---	---
Rm. 215 - Computer Room	Sink	Public Access	027	FN-S126	2	None	---	---	---	---	---	---
Rm. 215 - Computer Room	Fountain	Public Access	028	FN-F110	1.5	None	---	---	---	---	---	---
Rm. 216 - Computer Room	Sink	Public Access	029	FN-S125	1.6	None	---	---	---	---	---	---
Rm. 216 - Computer Room	Fountain	Public Access	030	FN-F109	1.1	None	---	---	---	---	---	---
Rm. 220A - Classroom Bathroom	Sink	Public Access	---	FN-S121	---	See Note 7.	001	<1.0	None	---	---	---
Rm. 228B - Office Kitchenette	Sink	Secured - SCSD Staff Only	031	FN-S118	<1.0	None	---	---	---	---	---	---
Rm. 234 - Hallway/Corridor	Fountain	Public Access	033	FN-F111	<1.0	None	---	---	---	---	---	---
Rm. 307 - Hallway/Vestibule	Sink	Public Access	008	FN-S139	1.2	None	---	---	---	---	---	---
Rm. 307 - Hallway/Vestibule	Sink	Public Access	006	FN-S140	<1.0	None	---	---	---	---	---	---
Rm. 307 - Hallway/Vestibule	Sink	Public Access	005	FN-S141	<1.0	None	---	---	---	---	---	---
Rm. 307 - Hallway/Vestibule	Fountain	Public Access	007	FN-F114	<1.0	None	---	---	---	---	---	---
Rm. 309 - Classroom	Fountain	Public Access	009	FN-F113	1	None	---	---	---	---	---	---
Rm. 310 - Classroom	Sink	Public Access	010	FN-S137	2.8	None	---	---	---	---	---	---
Rm. 310 - Classroom	Fountain	Public Access	011	FN-F112	1.3	None	---	---	---	---	---	---
Rm. 319 - Hallway/Vestibule	Sink	Public Access	001	FN-S219	2.4	None	---	---	---	---	---	---

**SYRACUSE CITY SCHOOL DISTRICT
FRANKLIN ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	07/21/23 RESULTS (ppb)	07/21 /23 ACTIONS	LAB RE-SAMPLE I.D. No.	04/03/24 RE-SAMPLE RESULTS (ppb)	04/03/24 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	10/22/25 RE-SAMPLE RESULTS (ppb)	10/22/25 RE-SAMPLE ACTIONS
Rm. 319 - Hallway/Vestibule	Sink	Public Access	002	FN-S220	<1.0	None	---	---	---	---	---	---
Rm. 319 - Hallway/Vestibule	Sink	Public Access	004	FN-S221	3.0	None	---	---	---	---	---	---
Rm. 319 - Hallway/Vestibule	Fountain	Public Access	003	FN-F208	1.3	None	---	---	---	---	---	---
Rm. 131 - Kitchen	iCombi Pro Oven Sprayer	Secured - SCSD Staff Only	042	FN-S4000	3.3	None	---	---	---	---	---	---
Rm. 322A - Hallway/Vestibule	Fountain	Public Access	---	F501	---	---	---	---	---	005	<1.0	None.
Rm. 322A - Hallway/Vestibule	Bottle Fill	Public Access	---	F501A	---	---	---	---	---	006	<1.0	None.
Rm. 237 - Hallway/Vestibule	Fountain	Public Access	---	F502	---	---	---	---	---	003	<1.0	None.
Rm. 237 - Hallway/Vestibule	Bottle Fill	Public Access	---	F502A	---	---	---	---	---	004	<1.0	None.

Notes [July 21, 2023 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-007.
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70264172.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture removed and replaced by SCSD.
7. Fixture repaired by SCSD.
8. Fixture signed by SCSD. No further action required.

Notes [April 3, 2024 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-007.
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70292835.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fountain removed and replaced with combined fountain and bottle fill station.

Notes [October 22, 2025 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-007.
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70387562.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.