

**SYRACUSE CITY SCHOOL DISTRICT  
MEACHEM ELEMENTARY SCHOOL**

ROOM No. & LOCATION	Fixture (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	08/01/23 RESULTS (ppb)	08/01/23 ORIGINAL ACTIONS	LAB RE-SAMPLE I.D. No.	01/11/2024 RE-SAMPLE RESULTS (ppb)	01/11/2024 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	10/22/2025 RE-SAMPLE RESULTS (ppb)	10/22/2025 RE-SAMPLE ACTIONS
Rm. 002 - Cafeteria	Fountain	Public Access	006	MM-F100	<1.0	None	---	---	See Note 6.	003	<1.0	None.
Rm. 002 - Cafeteria	Bottle Fill	Public Access	---	MM-F100A	---	---	---	---	---	004	<1.0	None.
Rm. 005 - Hallway/Corridor	Fountain	Public Access	007	MM-F101	<1.0	None	---	---	---	---	---	---
Rm. 005 - Hallway/Corridor	Fountain	Public Access	008	MM-F102	<1.0	None	---	---	See Note 6.	005	<1.0	None.
Rm. 005 - Hallway/Corridor	Bottle Fill	Public Access	---	MM-F102A	---	---	---	---	---	006	<1.0	None.
Rm. 023 - Hallway/Corridor	Fountain	Public Access	001	MM-F103	<1.0	None	---	---	See Note 6.	001	<1.0	None.
Rm. 023 - Hallway/Corridor	Bottle Fill	Public Access	---	MM-F103A	---	---	---	---	---	002	<1.0	None.
Rm. 026 - Kitchen	Sink	Secured - SCSD Staff Only	003	MM-S103	2.6	None	---	---	---	---	---	---
Rm. 026 - Kitchen	Sink	Secured - SCSD Staff Only	004	MM-S104	1.7	None	---	---	---	---	---	---
Rm. 026 - Kitchen	Sink	Secured - SCSD Staff Only	005	MM-S105	<1.0	None	---	---	---	---	---	---
Rm. 100E - Hallway/Corridor	Fountain	Public Access	039	MM-F104	<1.0	None	---	---	See Note 6.	011	<1.0	None.
Rm. 100E - Hallway/Corridor	Bottle Fill	Public Access	---	MM-F104A	---	---	---	---	---	012	<1.0	None.
Rm. 100E - Hallway/Corridor	Fountain	Public Access	040	MM-F105	<1.0	None	---	---	---	---	---	---
Rm. 100E - Hallway/Corridor	Fountain	Public Access	041	MM-F106	<1.0	None	---	---	---	---	---	---
Rm. 103 - Teacher's Lounge	Sink	Secured - SCSD Staff Only	042	MM-S121	<1.0	None	---	---	---	---	---	---
Rm. 104A - Exam Room	Sink	Public Access	043	MM-S123	1.3	None	---	---	---	---	---	---
Rm. 105 - Computer Lab	Sink	Public Access	044	MM-S124	3.9	None	---	---	---	---	---	---
Rm. 108 - Classroom	Sink	Public Access	045	MM-S128	1.1	None	---	---	---	---	---	---
Rm. 108 - Classroom	Fountain	Public Access	046	MM-F107	40.0	See Note 7.	003	<1.0	None	---	---	---
Rm. 108 - Classroom	Sink	Public Access	047	MM-S129	3.2	None	---	---	---	---	---	---
Rm. 110 - Classroom	Sink	Public Access	048	MM-S131	1.2	None	---	---	---	---	---	---
Rm. 110 - Classroom	Fountain	Public Access	049	MM-F108	2.2	None	---	---	---	---	---	---
Rm. 111 - Classroom	Fountain	Public Access	016	MM-F113	1.8	None	---	---	---	---	---	---
Rm. 112 - Classroom	Fountain	Public Access	019	MM-F111	1.2	None	---	---	---	---	---	---
Rm. 113 - Classroom	Fountain	Public Access	015	MM-F114	6.9	See Note 7.	006	1.2	None	---	---	---
Rm. 114 - Classroom	Sink	Public Access	018	MM-S139	4.3	None	---	---	---	---	---	---
Rm. 114 - Classroom	Fountain	Public Access	017	MM-F112	4.1	None	---	---	---	---	---	---
Rm. 115 - Classroom	Fountain	Public Access	014	MM-F115	2.1	None	---	---	---	---	---	---
Rm. 116 - Classroom	Sink	Public Access	013	MM-S143	1.0	None	---	---	---	---	---	---
Rm. 116 - Classroom	Fountain	Public Access	012	MM-F116	1.1	None	---	---	---	---	---	---
Rm. 117 - Classroom	Fountain	Public Access	011	MM-F117	1.5	None	---	---	---	---	---	---
Rm. 119 - Classroom	Fountain	Public Access	010	MM-F118	<1.0	None	---	---	---	---	---	---
Rm. 128 - Hallway/Corridor	Fountain	Public Access	050	MM-F109	<1.0	None	---	---	---	---	---	---
Rm. 128 - Hallway/Corridor	Fountain	Public Access	051	MM-F110	<1.0	None	---	---	---	---	---	---
Rm. 128 - Hallway/Corridor	Fountain(Sensor)	Public Access	---	MM-F110A	<1.0	None	---	---	---	---	---	---
Rm. 130A - Hallway/Vestibule	Sink	Public Access	020	MM-S133	2.3	None	---	---	---	---	---	---
Rm. 130A - Hallway/Vestibule	Sink	Public Access	021	MM-S134	1.3	None	---	---	---	---	---	---
Rm. 130A - Hallway/Vestibule	Sink	Public Access	022	MM-S135	<1.0	None	---	---	---	---	---	---

**SYRACUSE CITY SCHOOL DISTRICT  
MEACHEM ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	08/01/2023 RESULTS (ppb)	08/01/2023 ORIGINAL ACTIONS	LAB RE- SAMPLE I.D. No.	01/11/2024 RE-SAMPLE RESULTS (ppb)	01/11/2024 RE-SAMPLE ACTIONS	LAB RE- SAMPLE I.D. No.	10/22/2025 RE-SAMPLE RESULTS (ppb)	10/22/2025 RE-SAMPLE ACTIONS
Rm. 130A - Hallway/Vestibule	Sink	Public Access	023	MM-S136	7.4	See Note 6.	004	<1.0	None	---	---	---
Rm. 130A - Hallway/Vestibule	Sink	Public Access	024	MM-S137	15.8	See Note 6.	005	<1.0	None	---	---	---
Rm. 141 - Group Instruction Room	Sink	Secured - SCSD Staff Only	009	MM-S113	6.0	See Note 6.	001	3.3	None	---	---	---
Rm. 219 - Hallway/Corridor	Fountain	Public Access	031	MM-F121	<1.0	None	---	---	---	---	---	---
Rm. 219 - Hallway/Corridor	Bottle Fill	Public Access	---	MM-F122A	---	---	---	---	---	010	<1.0	None.
Rm. 219 - Hallway/Corridor	Fountain	Public Access	032	MM-F122	<1.0	None	---	---	See Note 6.	009	<1.0	None.
Rm. 223A - Library Office	Sink	Secured - SCSD Staff Only	038	MM-S157	4.6	None	---	---	---	---	---	---
Rm. 226 - Hallway/Vestibule	Sink	Public Access	033	MM-S152	56.6	See Note 6.	007	<1.0	None	---	---	---
Rm. 226 - Hallway/Vestibule	Sink	Public Access	034	MM-S153	31.9	See Note 6.	008	<1.0	None	---	---	---
Rm. 226 - Hallway/Vestibule	Sink	Public Access	035	MM-S154	<1.0	None	---	---	---	---	---	---
Rm. 226 - Hallway/Vestibule	Sink	Public Access	036	MM-S155	2.0	None	---	---	---	---	---	---
Rm. 226 - Hallway/Vestibule	Sink	Public Access	037	MM-S156	2.5	None	---	---	---	---	---	---
Rm. 228 - Hallway/Corridor	Fountain	Public Access	025	MM-F119	<1.0	None	---	---	---	---	---	---
Rm. 228 - Hallway/Corridor	Fountain	Public Access	026	MM-F120	<1.0	None	---	---	See Note 6.	007	<1.0	None.
Rm. 228 - Hallway/Corridor	Bottle Fill	Public Access	---	MM-F120A	---	---	---	---	---	008	<1.0	None.
Rm. 231 - Hallway/Vestibule	Sink	Public Access	027	MM-S147	1.2	None	---	---	---	---	---	---
Rm. 231 - Hallway/Vestibule	Sink	Public Access	028	MM-S148	<1.0	None	---	---	---	---	---	---
Rm. 231 - Hallway/Vestibule	Sink	Public Access	029	MM-S149	1.2	None	---	---	---	---	---	---
Rm. 231 - Hallway/Vestibule	Sink	Public Access	030	MM-S150	<1.0	None	---	---	---	---	---	---
Rm. 026 - Kitchen	Convootherm Oven Sprayer	Secured - SCSD Staff Only	002	MM-C1000	<1.0	None	---	---	---	---	---	---
Rm. 105 - Computer Lab	Sink	Public Access	---	MM-S124	---	---	002	3.3	None	---	---	---

Notes: [August 1, 2023 Event]

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-021.
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70265233.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture removed and replaced by SCSD. Resampling pending.
7. Fixture repaired by SCSD. Resampling pending.

Notes: [January 11, 2024 Event]

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-021.
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70283999.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fountain removed and replaced with combined fountain and bottle fill station.

SYRACUSE CITY SCHOOL DISTRICT  
MEACHEM ELEMENTARY SCHOOL

Notes: [October 22, 2025 Event]

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-021.
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70387568.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.