

SYRACUSE CITY SCHOOL DISTRICT  
ROBERTS PK-GRADE 8 SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	07/07/23 RESULTS (ppb)	07/07/23 ORIGINAL ACTIONS	LAB RE-SAMPLE I.D. No.	01/26/24 RE-SAMPLE RESULTS (ppb)	01/26/24 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	10/22/25 RE-SAMPLE RESULTS (ppb)	10/22/25 RE-SAMPLE ACTIONS
Rm. 122 - Receiving Room	Sink	Secured - SCSD Staff Only	014	RS-S311	2.0	None	---	---	---	---	---	---
Rm. 128 - Kitchen	Sink	Secured - SCSD Staff Only	012	RS-S306	7.5	See Note 7.	001	2.3	None	---	---	---
Rm. 128 - Kitchen	Sink	Secured - SCSD Staff Only	011	RS-S307	3.2	None	---	---	---	---	---	---
Rm. 128 - Kitchen	Sink	Secured - SCSD Staff Only	010	RS-S308	2.0	None	---	---	---	---	---	---
Rm. 128 - Kitchen	Sink	Secured - SCSD Staff Only	009	RS-S309	2.4	None	---	---	---	---	---	---
Rm. 132 - Hallway/Vestibule	Sink	Public Access	001	RS-S301	<1.0	None	---	---	---	---	---	---
Rm. 132 - Hallway/Vestibule	Sink	Public Access	002	RS-S302	1.4	None	---	---	---	---	---	---
Rm. 132 - Hallway/Vestibule	Sink	Public Access	003	RS-S303	1.1	None	---	---	---	---	---	---
Rm. 132 - Hallway/Vestibule	Sink	Public Access	004	RS-S304	1.3	None	---	---	---	---	---	---
Rm. 132 - Hallway/Vestibule	Sink	Public Access	005	RS-S305	1	None	---	---	---	---	---	---
Rm. 132 - Hallway/Corridor	Fountain	Public Access	006	RS-F301	<1.0	None	---	---	---	---	---	---
Rm. 132 - Hallway/Corridor	Fountain (Sensor)	Public Access	007	RS-F301A	<1.0	None	---	---	---	---	---	---
Rm. 132 - Hallway/Corridor	Fountain	Public Access	008	RS-F302	<1.0	None	---	---	---	---	---	---
Rm. 151A - Kitchen	Sink	Secured - SCSD Staff Only	015	RS-S110	3.1	None	---	---	---	---	---	---
Rm. 158 - Classroom	Sink	Public Access	020	RS-S105	<1.0	None	---	---	---	---	---	---
Rm. 158 - Classroom	Fountain	Public Access	021	RS-F102	<1.0	None	---	---	---	---	---	---
Rm. 159 - Classroom	Sink	Public Access	019	RS-S103	<1.0	None	---	---	---	---	---	---
Rm. 159 - Classroom	Fountain	Public Access	018	RS-F101	<1.0	None	---	---	---	---	---	---
Rm. 161 - Classroom	Sink	Public Access	016	RS-S107	<1.0	None	---	---	---	---	---	---
Rm. 161 - Classroom	Fountain	Public Access	017	RS-F103	<1.0	None	---	---	---	---	---	---
Rm. 274 - Classroom	Sink	Public Access	023	RS-S112	<1.0	None	---	---	---	---	---	---
Rm. 211 - Classroom	Sink	Public Access	044	RS-S207	2.8	None	---	---	---	---	---	---
Rm. 211 - Classroom	Fountain	Public Access	043	RS-F203	<1.0	None	---	---	---	---	---	---
Rm. 214 - Classroom	Sink	Public Access	045	RS-S209	5.1	See Note 6.	002	<1.0	None	---	---	---
Rm. 214 - Classroom	Fountain	Public Access	046	RS-F204	<1.0	None	---	---	---	---	---	---
Rm. 215 - Hallway/Corridor	Fountain	Public Access	039	RS-F201	<1.0	None	---	---	See Note 6.	007	<1.0	None.
Rm. 215 - Hallway/Corridor	Bottle Fill	Public Access	---	RS-F201A	---	---	---	---	---	008	<1.0	None.
Rm. 215 - Hallway/Corridor	Fountain	Public Access	040	RS-F202	<1.0	None	---	---	See Note 6.	009	<1.0	None.
Rm. 215 - Hallway/Corridor	Bottle Fill	Public Access	---	RS-F202A	---	---	---	---	---	010	<1.0	None.

SYRACUSE CITY SCHOOL DISTRICT  
ROBERTS PK-GRADE 8 SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	07/07/23 RESULTS (ppb)	07/07/23 ORIGINAL ACTIONS	LAB RE-SAMPLE I.D. No.	01/26/24 RE-SAMPLE RESULTS (ppb)	01/26/24 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	10/22/25 RE-SAMPLE RESULTS (ppb)	10/22/25 RE-SAMPLE ACTIONS
Rm. 219 - Teacher's Lounge	Fountain	Public Access	041	RS-F108	1.1	None	---	---	---	---	---	---
Rm. 220 - Hallway/Vestibule	Sink	Public Access	035	RS-S202B	<1.0	None	---	---	---	---	---	---
Rm. 220 - Hallway/Vestibule	Sink	Public Access	036	RS-S203	1.2	None	---	---	---	---	---	---
Rm. 220 - Hallway/Vestibule	Sink	Public Access	037	RS-S204	<1.0	None	---	---	---	---	---	---
Rm. 220 - Hallway/Vestibule	Sink	Public Access	038	RS-S205	<1.0	None	---	---	---	---	---	---
Rm. 220 - Hallway/Vestibule	Sink	Public Access	034	RS-S201B	<1.0	None	---	---	---	---	---	---
Rm. 239 - Hallway/Corridor	Fountain	Public Access	048	RS-F205	1.1	None	---	---	See Note 6.	005	<1.0	None.
Rm. 239 - Hallway/Corridor	Bottle Fill	Public Access	---	RS-F205A	---	---	---	---	---	006	<1.0	None.
Rm. 239 - Hallway/Corridor	Fountain	Public Access	050	RS-F107	<1.0	None	---	---	See Note 6.	003	<1.0	None.
Rm. 239 - Hallway/Corridor	Bottle Fill	Public Access	---	RS-F107A	---	---	---	---	---	004	<1.0	None.
Rm. 244 - Office	Sink	Secured - SCSD Staff Only	047	RS-S211	2.7	None	---	---	---	---	---	---
Rm. 255 - Office Kitchenette	Sink	Secured - SCSD Staff Only	049	RS-S125	1.3	None	---	---	---	---	---	---
Rm. 263 - Nurse's Room	Sink	Public Access	051	RS-S118	1.3	None	---	---	---	---	---	---
Rm. 267 - Kitchen/Teacher's Lounge	Sink	Secured - SCSD Staff Only	042	RS-S120	1.1	None	---	---	---	---	---	---
Rm. 272 - Classroom	Sink	Public Access	027	RS-S116	<1.0	None	---	---	---	---	---	---
Rm. 272 - Classroom	Fountain	Public Access	026	RS-F106	<1.0	None	---	---	---	---	---	---
Rm. 273 - Classroom	Sink	Public Access	024	RS-S114	<1.0	None	---	---	---	---	---	---
Rm. 273 - Classroom	Fountain	Public Access	025	RS-F105	<1.0	None	---	---	---	---	---	---
Rm. 274 - Classroom	Fountain	Public Access	022	RS-F104	<1.0	None	---	---	---	---	---	---
Rm. 313 - Classroom	Sink	Public Access	032	RS-S320	5.6	See Note 6.	003	2.4	None	---	---	---
Rm. 313 - Classroom	Sink	Public Access	033	RS-S321	<1.0	None	---	---	---	---	---	---
Rm. 325 - Hallway/Vestibule	Sink	Public Access	029	RS-S318	1.2	None	---	---	---	---	---	---
Rm. 325 - Hallway/Vestibule	Sink	Public Access	030	RS-S319	<1.0	None	---	---	---	---	---	---
Rm. 327 - Hallway/Vestibule	Sink	Public Access	028	RS-S315	1.9	None	---	---	---	---	---	---
Rm. 329 - Hallway/Corridor	Fountain	Public Access	031	RS-F303	<1.0	None	---	---	See Note 6.	001	<1.0	None.
Rm. 329 - Hallway/Corridor	Bottle Fill	Public Access	---	RS-F303A	---	---	---	---	---	002	<1.0	None.
Rm. 151A - Kitchen	iCombi Pro Oven Sprayer	Secured - SCSD Staff Only	013	RS-C1000A	1.6	None	---	---	---	---	---	---

SYRACUSE CITY SCHOOL DISTRICT  
ROBERTS PK-GRADE 8 SCHOOL

Notes: [July 7, 2023 Event]

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-014
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70262549.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture removed, replaced and resampled.
7. Fixture repaired and resampled.

Notes: [January 26, 2024 Event]

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-014
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70285513.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture removed and replaced with combined fountain and bottle fill station.

Notes: [October 22, 2025 Event]

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-014
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70387567.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.