

**SYRACUSE CITY SCHOOL DISTRICT  
MSAP (SHEA) SCHOOL**

ROOM No. & LOCATION	Fixture (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	11/07/24 RESULTS (ppb)	11/07/24 ORIGINAL ACTIONS	LAB RE-SAMPLE I.D. No.	03/07/25 RE-SAMPLE RESULTS (ppb)	03/07/25 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	05/09/25 RE-SAMPLE RESULTS (ppb)	05/09/25 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	07/08/25 RE-SAMPLE RESULTS (ppb)	07/08/25 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	10/29/25 RE-SAMPLE RESULTS (ppb)	10/29/25 RE-SAMPLE ACTIONS
Rm. 106 - Kitchen	Sink	Secured - SCSD Staff Only	006	MSAP-S115	201	See Note 6.	002	5.7	See Note 6.	001	7.5	See Note 6.	001	5.5	See Note 6.	001	1.0	None.
Rm. 106 - Kitchen	Sink	Secured - SCSD Staff Only	001	MSAP-S117	3.9	None	---	---	---	---	---	---	---	---	---	---	---	
Rm. 106 - Kitchen	Sink	Secured - SCSD Staff Only	002	MSAP-S118	63.4	See Note 6.	001	<1.0	None	---	---	---	---	---	---	---	---	
Rm. 106 - Kitchen	Sink	Secured - SCSD Staff Only	003	MSAP-S119	4.1	None	---	---	---	---	---	---	---	---	---	---	---	
Rm. 106 - Kitchen	Sink	Secured - SCSD Staff Only	004	MSAP-S120	1.2	None	---	---	---	---	---	---	---	---	---	---	---	
Rm. 114 - Classroom	Sink	Public Access	009	MSAP-S105	5.9	See Note 6.	004	4.3	None	---	---	---	---	---	---	---	---	
Rm. 116 - Teacher's Lounge	Sink	Secured - SCSD Staff Only	008	MSAP-S100	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	
Rm. 120 - Girl's Locker Room	Fountain	Public Access	013	MSAP-F101	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	
Rm. 130A - Hallway/Corridor	Fountain	Public Access	007	MSAP-F103	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	
Rm. 130J - Hallway/Corridor	Fountain	Public Access	012	MSAP-F100	7.8	See Note 6.	006	2.2	None	---	---	---	---	---	---	---	---	
Rm. 211P - Storage Room	Sink	Secured - SCSD Staff Only	025	MSAP-S138	9.1	See Note 6.	011	8.6	See Note 6.	006	2.5	None	---	---	---	---	---	
Rm. 225 - Hallway/Corridor	Fountain	Public Access	026	MSAP-F104	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	
Rm. 225H - Hallway/Corridor	Fountain	Public Access	015	MSAP-F107	1.6	None	---	---	---	---	---	---	---	---	---	---	---	
Rm. 225J - Hallway/Vestibule	Fountain	Public Access	014	MSAP-F106	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	
Rm. 225N - Hallway/Corridor	Fountain	Public Access	018	MSAP-F105	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	
Rm. 225N - Hallway/Corridor	Fountain	Public Access	017	MSAP-F105A	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	
Rm. 235 - Exam Office	Sink	Public Access	023	MSAP-S141	5.1	See Note 6.	007	7.2	See Note 6.	005	1.6	None	---	---	---	---	---	
Rm. 237 - Nurse's Office	Sink	Public Access	020	MSAP-S145	6.1	See Note 6.	009	19.3	See Note 6.	003	1.5	None	---	---	---	---	---	
Rm. 238 - Exam Room	Sink	Public Access	022	MSAP-S143	6.7	See Note 6.	010	50.2	See Note 6.	004	7.3	See Note 6.	002	2.1	None	---	---	
Rm. 238 - Exam Room	Sink	Public Access	021	MSAP-S143A	42.6	See Note 6.	---	---	---	---	---	---	---	---	---	---	---	
Rm. 239 - Conference Room	Sink	Secured - SCSD Staff Only	024	MSAP-S142	2.4	None	---	---	---	---	---	---	---	---	---	---	---	
Rm. 245 - Clinic Office	Sink	Public Access	016	MSAP-S150	8.3	See Note 6.	005	1.8	None	---	---	---	---	---	---	---	---	
Kitchenette in Renovated Area	Sink	Public Access	010	MSAP-S1000	5.9	See Note 6.	003	1.5	None	---	---	---	---	---	---	---	---	
Kitchenette in Renovated Area	Sink	Public Access	011	MSAP-S1001	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	
Rm. 232 - Waiting Room	Sink	Public Access	019	MSAP-S3000	8.1	See Note 6.	008	7.5	See Note 6.	002	1.4	None	---	---	---	---	---	
Rm. 106 - Kitchen	Convotherm (Oven)	Secured - SCSD Staff Only	005	MSAP-C1001	3.7	None	---	---	---	---	---	---	---	---	---	---	---	

Notes [November 07, 2024 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-033
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70321289
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture repaired or replaced by SCSD.

Notes [March 07, 2025 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-033A
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70341939
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture repaired or replaced by SCSD.

SYRACUSE CITY SCHOOL DISTRICT  
MSAP (SHEA) SCHOOL

Notes [May 09, 2025 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-033A
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70354069
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. SCSD to evaluate fixture for repair or removal.

Notes [July 08, 2025 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-033
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70365850
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. SCSD to evaluate fixture for repair or removal.

Notes [October 29, 2025 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-033
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70388455.
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.