

**SYRACUSE CITY SCHOOL DISTRICT
SEYMOUR DUAL LANGUAGE ACADEMY SCHOOL PK-GRADE 5**

ROOM No. & LOCATION	Fixture (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	07/11/23 RESULTS (ppb)	07/11/2023 ORIGINAL ACTIONS	LAB RE-SAMPLE I.D. No.	04/17/24 RE-SAMPLE RESULTS (ppb)	04/17/24 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	06/13/25 RE-SAMPLE RESULTS (ppb)	06/13/25 RE-SAMPLE ACTIONS	LAB SAMPLE I.D. No.	10/15/25 SAMPLE RESULTS (ppb)	10/15/25 SAMPLE ACTIONS
Rm. 114 - Classroom	Fountain	Public Access	012	SR-F304	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 115 - Classroom	Fountain	Public Access	011	SR-F204	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 116 - Classroom	Fountain	Public Access	020	SR-S203	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 117 - Classroom	Sink	Public Access	019	SR-S208	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 117 - Classroom	Fountain	Public Access	018	SR-F202	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 119 - Classroom	Sink	Public Access	017	SR-S204	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 119 - Classroom	Fountain	Public Access	---	SR-F201	---	See Note 6.	001	<1.0	None	---	---	---	---	---	---
Rm. 123 - Hallway/Corridor	Fountain	Public Access	016	SR-F200	<1.0	None	---	---	---	001	<1.0	None	---	---	---
Rm. 123 - Hallway/Corridor	Fountain (Bottle Fill)	Public Access	---	SR-F200A	---	---	---	---	---	002	<1.0	None	---	---	---
Rm. 137 - Audio / Visual	Sink	Public Access	015	SR-A	1.4	None	---	---	---	---	---	---	---	---	---
Rm. 156 - Hallway/Corridor	Fountain	Public Access	014	SR-F303	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 156 - Hallway/Corridor	Fountain (Bottle Fill)	Public Access	---	SR-F303A	---	See Note 6.	003	<1.0	None	---	---	---	---	---	---
Rm. 175 - Exam Room	Sink	Public Access	013	SR-S326	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 176 - Cafeteria	Fountain	Public Access	001	SR-F305	<1.0	None	---	---	---	003	<1.0	None	---	---	---
Rm. 176 - Cafeteria	Fountain (Bottle Fill)	Public Access	---	SR-F305A	---	---	---	---	---	004	<1.0	None	---	---	---
Rm. 178 - Kitchen	Sink	Secured - SCSD Staff Only	002	SR-S210	1.3	None	---	---	---	---	---	---	---	---	---
Rm. 178 - Kitchen	Sink	Secured - SCSD Staff Only	004	SR-S211	1.9	None	---	---	---	---	---	---	---	---	---
Rm. 178 - Kitchen	Sink Hose	Secured - SCSD Staff Only	005	SR-S212	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 178 - Kitchen	Sink	Secured - SCSD Staff Only	003	SR-S213	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 178 - Kitchen	Upper Oven Sprayer	Secured - SCSD Staff Only	---	SR-C1000	---	---	---	---	---	---	---	---	001	3.2	None.
Rm. 178 - Kitchen	Lower Oven Sprayer	Secured - SCSD Staff Only	---	SR-C1001	---	---	---	---	---	---	---	---	002	22.9	See Note 6.
Rm. 221 - Teacher's Lounge	Sink	Secured - SCSD Staff Only	010	SR-S315	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 221G - Hallway/Vestibule	Fountain	Public Access	---	SR-F302	---	See Note 6.	002	<1.0	None	006	<1.0	None	---	---	---
Rm. 221G - Hallway/Vestibule	Fountain (Bottle Fill)	Public Access	---	SR-F302A	---	---	---	---	---	005	<1.0	None	---	---	---
Rm. 221G - Hallway/Vestibule	Sink	Public Access	008	SR-S307	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 221G - Hallway/Vestibule	Sink	Public Access	007	SR-S308	1.7	None	---	---	---	---	---	---	---	---	---
Rm. 222A - Classroom	Sink	Public Access	009	SR-S309	1.4	None	---	---	---	---	---	---	---	---	---
Rm. 232 - Hallway/Corridor	Fountain	Public Access	006	SR-F301	<1.0	None	---	---	---	007	<1.0	None	---	---	---
Rm. 232 - Hallway/Corridor	Fountain (Bottle Fill)	Public Access	---	SR-F301A	---	---	---	---	---	008	<1.0	None	---	---	---

Notes [July 11, 2023 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-016
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70262890.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture repaired by SCSD.

SYRACUSE CITY SCHOOL DISTRICT
SEYMOUR DUAL LANGUAGE ACADEMY SCHOOL PK-GRADE 5

Notes [April 17, 2024 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-016
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70294625.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.

Notes [June 13, 2025 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-016
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70361181.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.

Notes [October 15, 2025 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-016
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70386130.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture removed from service by SCSD.